

DOCUMENT 00 91 13

ADDENDUM No. 3

1.01 PROJECT INFORMATION

- A. Project Name: Town of Superior Fire Hall.
- B. Owner: Town of Superior.
- C. Architect: Benjamin Olson, AIA.
- D. Architect Project Number: 16940.000.
- E. Date of Addendum: February 26, 2019.

1.02 NOTICE TO BIDDERS

- A. This Addendum is issued plan holders pursuant to the Instructions to Bidders. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.

1.03 ATTACHMENTS

- A. This Addendum includes the following attached Documents and Specification Sections:
 - 1. Plan Holders List, dated February 26, 2019, (new).
 - 2. Document 00 31 26 "Existing Hazardous Material Information", dated February 26, 2019, (new).
 - 3. Pre-Demolition Hazardous Materials Inspection Report, dated February 25, 2019, (new).
 - a. The Fire Department will remove all items described as *Regulated Waste* with the exception of items identified on Sheet A700 FFE Schedule and the following: fluorescent bulbs, ballasts, exit signs, garage door openers, ceiling fans, electrical boxes, and thermostat.
 - 4. Document 00 41 00 "Bid Form-Stipulated Sum", dated February 26, 2019, (reissued).
- B. This Addendum includes the following attached Schedules:
 - 1. Door and Frame Schedule from Sheet A600, (reissued).

1.04 REVISIONS TO PREVIOUS ADDENDA

- A. Addendum No. 2: (not reissued).
 - 1. Paragraph 1.06.A.7: Replace *Answer* with the following: The General Contractor shall be responsible for **ALL** Testing and Special Inspections associated with the Work. The Owner will not engage an independent testing agency. Approved testing agencies are identified in Section 01 40 00 Paragraph 3.01.

1.05 REVISIONS TO DIVISION 00 PROCUREMENT REQUIREMENTS AND CONTRACTING REQUIREMENTS

A. Document 00 41 00 "Bid Form-Stipulated Sum", dated February 26, 2019, (reissued).

1. Paragraph 1.02: Paragraph omitted.

1.06 REVISIONS TO DIVISIONS 02 - 49 SPECIFICATION SECTIONS

A. Specification Section 08 71 00 "Door Hardware", (not reissued).

1. Paragraph 2.02.A.5: Add b. Ives
2. Paragraph 2.06.A.2: Add c. Falcon
3. Paragraph 2.09.B.1: Add d. Falcon
4. Paragraph 2.09.C.2: Add c. Falcon
5. Paragraph 2.10.B.1: Add e. LCN
6. Paragraph 2.10.C.1: Add d. LCN

B. Specification Section 08 71 15 "Automatic Door Operators", (not reissued).

1. Paragraph 2.01.A: Add 5. LCN 4640 Series AUTO EQUALIZER

C. Specification Section 23 54 00 "Furnaces", (not reissued).

1. Paragraph 2.01.A: Add 7. Goodman Air Conditioning & Heating

D. Specification Section 23 55 23 "Radiant Heat", (not reissued).

1. Paragraph 1.05: Add 4. Superior Radiant.

E. Specification Section 23 62 00 "Packaged Compressor and Condenser Units", (not reissued).

1. Paragraph 2.01.A: Add 5. Goodman Air Conditioning & Heating

1.07 REVISIONS TO DRAWING SHEETS

A. Sheet A600: Room Schedule, Door Schedule and Elevations, (not reissued).

1. Door and Frame Schedule: Replace with attached Door and Frame Schedule.
2. Room Finish Schedule: Storage 112 shall receive an ACT ceiling as indicated on the Reflected Ceiling Plan.
3. Room Schedule Notes: Add to Note No. 1. HPC Floor System shall consist of the following: 100% solids epoxy; prime coat Rust-Oleum Penetrating Prime and Seal Primer, finish coat Rust-Oleum 8000 OverKrete S, cove base Rust-Oleum OverKrete 8000 CB.
 - a. Approved equals include: Armorseal 650 by SW and Megaseal by PPG.

B. Sheet A700: Inventory Plan, (not reissued).

1. Fixture, Furniture, Equipment Schedule: Marks 2, 3, and 4. Existing gear locker manufacturer is Ready Rack.

- a. Clarification: The General Contractor shall provide and install a total of 15 new gear lockers (match existing) and relocate and install a total of 12 existing gear lockers.

END OF SECTION



11 East Superior Street, Suite 420
Duluth, MN 55802
218.724.8578
tkda.com

February 26, 2019

Town of Superior Fire Hall
TKDA Project No. 16940.000

Plan Holders List

A to Z Plumbing & Heating, Inc.
Benson Electric
Blakeman Plumbing & Heating
Bougalis & Sons
Donald Holm Construction Co., Inc.
Four Star Construction
Gardner Builder's
Hanco Utilities
Hovland Inc.
Jerome Excavating Contractors, LLC
Johnson Wilson Constructors, Inc.
Kaski, Inc.
Kraus-Anderson, Inc.
Lakehead Constructors, Incorporated
McCabe Construction
NORDIC Group
Rachel Contracting
Ray Riihilouma, Inc.
Stack Brothers
Structural Buildings
Structural Tower Services, Inc.
Superior Glass
Veit & Company, Inc.

DOCUMENT 00 31 26

EXISTING HAZARDOUS MATERIAL INFORMATION

1.01 EXISTING HAZARDOUS MATERIAL INFORMATION

- A. This Document with its referenced attachments is part of the Procurement and Contracting Requirements for Project. They provide Owner's information for Bidders' convenience and are intended to supplement rather than serve in lieu of Bidders' own investigations. They are made available for Bidders' convenience and information, but are not a warranty of existing conditions. This Document and its attachments are not part of the Contract Documents.
- B. A Pre-Demolition Hazardous Materials Inspection Report, prepared by Twin Ports Testing, Inc., dated February 25, 2019, is appended to this Document.
- C. Related Requirements:
 - 1. Document 002113 "Instructions to Bidders" for the Bidder's responsibilities for examination of Project site and existing conditions.
 - 2. Document 003119 "Existing Condition Information" for information about existing conditions that is made available to bidders.
 - 3. Document 003132 "Geotechnical Data" for reports and soil-boring data from geotechnical investigations that are made available to bidders.
 - 4. Section 024116 "Structure Demolition" for notification requirements if materials suspected of containing hazardous materials are encountered.

END OF DOCUMENT



PRE-DEMOLITION HAZARDOUS MATERIALS INSPECTION REPORT

Town of Superior
Fire Hall
5997 WI-35
Superior, Wisconsin

TPT#19A0115

Prepared for:

**Mr. Ronald Pete
Chairman
Town of Superior
Superior, Wisconsin 54880**

February 25, 2019

February 25, 2019

TPT #19A0115

Mr. Ronald Pete
Town of Superior
Chairman
Superior, WI 54880

Re: **Hazardous Materials Survey
Town of Superior
Fire Hall
5997 WI-35
Superior, Wisconsin**

Dear Mr. Pete:

The following is a final report outlining the asbestos and regulated waste inspection conducted at the subject site for demolition purposes. This report contains the following information:

- Introduction
- Results
- Recommendations

INTRODUCTION

Twin Ports Testing II, Inc. (TPT) was contracted by Mr. Ronald Pete, Chairman of the Town of Superior, to conduct an Asbestos and Regulated Waste Inspection prior to proposed demolition of the Town Fire Hall. The building is located at 5997 WI-35 in Superior, Wisconsin. On February 20th, 2019, Mr. Gary Christner, a Wisconsin Department of Health Services (WDHS) Certified Asbestos Inspector was on-site to collect material samples that potentially contain asbestos. Copies of the inspectors MDH hard card is included in Appendix A.

RESULTS

Asbestos

TPT collected eight samples that were potentially asbestos containing materials (ACM). These building materials included: rubber strip, wallboard, sheetrock, sheetrock (texture), ceramic tile, adhesive, grout and baseboard. TPT staff collected bulk samples from the suspect building components in accordance with the Wisconsin Department of Health Services (WDHS) regulations pertaining to asbestos inspections.

The table on the following page lists the areas that were sampled for asbestos (bold and shading indicates positive results), sample ID, location, and percent (%) asbestos (if applicable). Laboratory analytical results are included in Appendix B.

Table 1 – Sampled Material

Object or Item	Sample ID	Location	% Asbestos
Rubber strip	1	Around exterior doors, beige	None Detected
Rubber strip	2	Around interior doors, white	None Detected
Wallboard	3	Under plastic wall, bathroom, (brown/white/brown)	None Detected
Adhesive		Under plastic wall, bathroom, yellow	None Detected
Wallboard	4	Wallboard exposed wall, bathroom, (gray/tan/white)	None Detected
Ceiling sheetrock	5	Bathroom ceiling, (brown/white)	None Detected
Texture		Bathroom ceiling on sheetrock, white	None Detected
Ceramic tile	6	Bathroom floor, (gray/white)	None Detected
Adhesive		Bathroom floor under tile, tan	None Detected
Grout		Bathroom floor, gray	None Detected
Grout	7	Bathroom floor between tiles, gray	None Detected
Baseboard	8	Bathroom, white	None Detected
Adhesive		Bathroom under baseboard, tan	None Detected

By the WDHS rules and regulations, asbestos containing materials are materials that contain greater than 1% asbestos. None of the materials tested are considered to be Asbestos Containing Materials (ACMs).

Regulated Waste

TPT identified the following items that must be removed and properly disposed of before demolition. The following list is merely a guideline for removal; items may have been missed and quantities may not be exact. Any additional regulated waste that is discovered should be removed prior to demolition.

Main Bay Area:

- 32 Fluorescent bulbs
- 14 Ballasts
- 1 Refrigerator
- 2 Exit Signs
- 6 Garage Door Openers
- 3 Ceiling Fans
- 3 Electrical Boxes
- 1 Mercury Thermostat
- 1 150 Fl. Oz. of Tide
- 1 Gallon of Shock Wave
- 2 Gallons of Windshield Fluid
- 1 Washer
- 1 Dryer
- 1 12oz Rust-oleum
- 2 Water Heaters
- 2 Gallons Orange Hand Cleaner
- 5 5 Gallon Fire Brake Foam
- 1 Gallon Dalmation Wash & Wax
- 1 13oz. Aero Kroil
- 1 5 Gallon Medallium Plus Deisel

Main Bay Area (Cont:

- 1 55 Gallon Oil Drum (Plastic)
- 1 5 Gallon Silv-Ex Fire Control
- 1 Freezer
- Misc. Cleaning Supplies (Above Utility Sink)

Bathroom:

- 1 12oz Oust
- 1 25oz Scubbing Bubbles
- 10 1.25 Hand Wash
- 1 32oz Lysol

- 1 32oz Tub Cleaner
- 1 Gallon Hi-Tor Plus
- 1 Gallon Impregnator Seal
- 1 Hand Sanitizer
- 1 9.7oz of Fabreez
- 1 4oz Gold Bond Body Powder
- 1 Hand Soap
- 1 Box Provon Hand Lotion
- Misc. Cleaning Supplies (Under Sink)

RECOMMENDATIONS


If additional materials are discovered that may be asbestos containing during demolition, the material must be tested or assumed to be asbestos containing and treated as such.

TPT recommends proper removal and disposal of the regulated wastes prior to demolition.

This inspection was conducted according to federal, state and local regulations. If you have any questions regarding this report, please feel free to contact me at (715) 392-7114 (office). Thank you for the opportunity to conduct this work.

Sincerely,

Twin Ports Testing II, Inc.



Gary Christner
Industrial Hygiene Technician
Inspector #All-106722

2-25-19

Date

Attachments: Appendix A: Inspector Certifications
Appendix B: Asbestos Laboratory Analytical Results

Appendix A

Inspector Certifications



ASBESTOS INSPECTOR

Issued By

STATE OF WISCONSIN

Dept. of Health Services

Gary Jerome Christner

2337 Pershing St

Duluth MN 55811-3028

		200 lbs	5' 09"
AI-106722	Exp: 03/04/2020	08/12/1966	

Training due by 03/04/2020

Appendix B

Asbestos Laboratory Analytical Results

**EMSL Analytical, Inc.**

14375 23rd Avenue North Minneapolis, MN 55447

Tel/Fax: (763) 449-4922 / (763) 449-4924

<http://www.EMSL.com/minneapolislab@emsl.com>**EMSL Order:** 351901005**Customer ID:** TWNT42**Customer PO:****Project ID:****Attention:** Tracy Jacobs

Twin Ports Testing II, Inc.

1301 North Third Street

Superior, WI 54880

Phone: (218) 390-0162**Fax:****Received Date:** 02/22/2019 9:40 AM**Analysis Date:** 02/22/2019**Collected Date:****Project:** 19A0115 Town of Superior Fire Hall**Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy**

Sample	Description	Appearance	Non-Asbestos		Asbestos % Type
			% Fibrous	% Non-Fibrous	
1 351901005-0001	Rubber strip around Ext. Door, beige	Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
2 351901005-0002	Rubber strip around Int. Door, white	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
3-Wallboard 351901005-0003	Wallboard under plastic wall, bathroom, tan/white/brown	Brown/Tan/White Non-Fibrous Heterogeneous	15% Cellulose	85% Non-fibrous (Other)	None Detected
3-Adhesive 351901005-0003A	Wallboard under plastic wall, bathroom, tan/white/brown	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
4 351901005-0004	Wallboard exposed wall, bathroom, gray/white	Gray/Tan/White Non-Fibrous Heterogeneous	10% Cellulose 5% Glass	85% Non-fibrous (Other)	None Detected
5-Ceiling Sheetrock 351901005-0005	Ceiling Sheetrock & texture, bathroom, white/brown	Brown/White Non-Fibrous Heterogeneous	15% Cellulose	85% Non-fibrous (Other)	None Detected
5-Texture 351901005-0005A	Ceiling Sheetrock & texture, bathroom, white/brown	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
6-Ceramic Tile 351901005-0006	Ceramic tile, bathroom floor, white/gray	Gray/White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
6-Adhesive 351901005-0006A	Ceramic tile, bathroom floor, white/gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
6-Grout 351901005-0006B	Ceramic tile, bathroom floor, white/gray	Gray Non-Fibrous Homogeneous	2% Cellulose	98% Non-fibrous (Other)	None Detected
7 351901005-0007	Grout between ceramic tile, gray	Gray Non-Fibrous Homogeneous	2% Cellulose	98% Non-fibrous (Other)	None Detected
8-Baseboard 351901005-0008	Baseboard, bathroom, tan/white	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
8-Adhesive 351901005-0008A	Baseboard, bathroom, tan/white	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected

Initial report from: 02/22/2019 17:37:41



EMSL Analytical, Inc.

14375 23rd Avenue North Minneapolis, MN 55447

Tel/Fax: (763) 449-4922 / (763) 449-4924

<http://www.EMSL.com> / minneapolislab@emsl.com

EMSL Order: 351901005

Customer ID: TWNT42

Customer PO:

Project ID:

Analyst(s)

Ben Bunge (13)

Rachel Travis, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method"), but augmented with procedures outlined in the 1993 ("final") version of the method. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. All samples received in acceptable condition unless otherwise noted. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. EMSL recommends gravimetric reduction for all non-friable organically bound materials prior to analysis. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Minneapolis, MN NVLAP Lab Code 200019-0

Initial report from: 02/22/2019 17:37:41

EMSL Analytical, Inc.
14375 23rd Avenue North

Asbestos Chain of Custody

EMSL Order Number (Lab Use Only):

1005

 Minneapolis, MN 55447
 PHONE: (763) 449-4922
 FAX: (763) 449-4924

Company Name : Twin Ports Testing II		EMSL Customer ID:	
Street: 1301 North 3rd Street		City: Superior	State/Province: WI
Zip/Postal Code: 54880	Country: US	Telephone #: (218) 390-0162	Fax #: 7153927163
Report To (Name): Tracy Jacobs		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email	
Email Address: tracy.jacobs@twinportstesting.com		Purchase Order:	
Project Name/Number: 19A0116 Town of Superior Fire Hall		EMSL Project ID (Internal Use Only):	
U.S. State Samples Taken: MN WI		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	
EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different - If Bill to is Different note instructions in Comments** Third Party Billing requires written authorization from third party			
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input checked="" type="checkbox"/> 24 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week			
*For TEM Air 3 hr through 6 hr, please call ahead to schedule. *There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.			
PCM - Air <input type="checkbox"/> Check if samples are from NY <input type="checkbox"/> NIOSH 7400 <input type="checkbox"/> w/ OSHA 8hr. TWA		TEM - Air <input type="checkbox"/> 4-4.5hr TAT (AHERA only) <input type="checkbox"/> AHERA 40 CFR, Part 763 <input type="checkbox"/> NIOSH 7402 <input type="checkbox"/> EPA Level II <input type="checkbox"/> ISO 10312	
PLM - Bulk (reporting limit) <input checked="" type="checkbox"/> PLM EPA 600/R-93/116 (<1%) <input type="checkbox"/> PLM EPA NOB (<1%) Point Count <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) Point Count w/Gravimetric <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) <input type="checkbox"/> NYS 198.1 (friable in NY) <input type="checkbox"/> NYS 198.6 NOB (non-friable-NY) <input type="checkbox"/> NYS 198.8 SOF-V <input type="checkbox"/> NIOSH 9002 (<1%)		TEM - Bulk <input type="checkbox"/> TEM EPA NOB <input type="checkbox"/> NYS NOB 198.4 (non-friable-NY) <input type="checkbox"/> Chatfield SOP <input type="checkbox"/> TEM Mass Analysis-EPA 600 sec. 2.5 TEM - Water: EPA 100.2 Fibers >10µm <input type="checkbox"/> Waste <input type="checkbox"/> Drinking All Fiber Sizes <input type="checkbox"/> Waste <input type="checkbox"/> Drinking	
TEM - Dust <input type="checkbox"/> Microvac - ASTM D 5755 <input type="checkbox"/> Wipe - ASTM D6480 <input type="checkbox"/> Carpet Sonication (EPA 600/J-93/167)		Soil/Rock/Vermiculite <input type="checkbox"/> PLM EPA 600/R-93/116 with milling prep (<1%) <input type="checkbox"/> PLM EPA 600/R-93/116 with milling prep (<0.25%) <input type="checkbox"/> TEM EPA 600/R-93/116 with milling prep (<0.1%) <input type="checkbox"/> TEM Qualitative via Filtration Prep <input type="checkbox"/> TEM Qualitative via Drop Mount Prep <input type="checkbox"/> Cincinnati Method EPA 600/R-04/004 - PLM/TEM (BC only)	
<input type="checkbox"/> Check For Positive Stop - Clearly Identify Homogenous Group		Filter Pore Size (Air Samples): <input type="checkbox"/> 0.8µm <input type="checkbox"/> 0.45µm	
Samplers Name: Gary Christner		Samplers Signature: Gary Christner	
Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
1	Ext. Rubber strip around Ext. Door, beige		
2	Rubber strip around Int. Door, white		
3	Wallboard under plastic wall, bathroom, tan/white/brown		
4	Wallboard exposed wall, bathroom, grey/white		
5	Ceiling Sheetrock & texture, bathroom, white/brown		
Client Sample # (s): 1 - 8		Total # of Samples: 8	
Relinquished (Client): Gary Christner		Date: 2-20-19	Time: 10:00
Received (Lab): Alindahl & Fox 7956 73941830		Date: 2-22-19	Time: 9:40
Comments/Special Instructions:			



Asbestos Chain of Custody
EMSL Order Number (Lab Use Only):

EMSL Analytical, Inc.
14375 23rd Avenue North

Minneapolis, MN 55447
PHONE: (763) 449-4922
FAX: (763) 449-4924

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

DOCUMENT 00 41 00
FIRE HALL
TOWN OF SUPERIOR
BID FORM

Bid Due Date: March 5, 2019

Bid To: Town of Superior
4917 South State Highway 35
Superior, WI 54880

ARTICLE 1 - BASE BID

- 1.01 The undersigned, having, examined the site of the Work, reviewed the plans and specifications for the Work as prepared by TKDA, dated 01/18/19, and being familiar with the conditions affecting the Work; propose to furnish all labor, material, skills and equipment necessary for the complete construction of , for the lump sum (Base Bid) of:

_____ Dollars (\$_____)

Note: Materials removed under Section 02 41 16, not scheduled, indicated, or directed to be salvaged for the Owner benefit, which have commercial value may be sold; but if such is the case, bidders shall make appropriate adjustments for such value in their bid.

ARTICLE 2 - ACKNOWLEDGEMENTS AND COVENANTS

- 2.01 In the event of a discrepancy between the written words and numeral amounts in this Bid, the written words shall govern.
- 2.02 Receipt is acknowledged of Addenda Nos. _____, _____, and _____.
- 2.03 Bid security as specified in the Advertisement for Bids is enclosed, and is offered subject to the terms specified therein.
- 2.04 This bid may not be rescinded for a period of 60 days from the Bid Opening Date.
- 2.05 If this Bid is accepted, we will execute a contract in the form referenced in the Project Manual.
- 2.06 If this Bid is accepted, we will furnish bonds in the full amount of the contract, and in the forms specified in the Project Manual.
- 2.07 If this Bid is accepted, we will complete the work as specified on or before:
_____, 20____, but in no case no later than 12 months
after the Notice to Proceed.
- 2.08 The undersigned states that it is a duly licensed contractor, for the type of work proposed, in the State of Wisconsin, and that all fees, permits, etc., pursuant to submitting this proposal have been paid in full.

2.09 Bid From,

Firm Name: _____

Signed by: _____

Address: _____

_____ Zip _____

END OF SECTION

DOOR & FRAME SCHEDULE															
DOOR NO.	DOOR					FRAME			DETAIL REFERENCE			GLAZING TYPE	LABEL	HWDE. GROUP	NOTES
	WIDTH	HEIGHT	TYPE	MATERIAL	FINISH	TYPE	MATERIAL	FINISH	HEAD	JAMB	SILL				
100	3' - 0"	7' - 0"	D2	F.R.P.	PREFIN.	F1	F.R.P	PREFIN.	5/A650	5/A650	7/A650	GL-1	-	6.00	-
100A	3' - 0"	7' - 0"	D2	H.M.	PT	F1	H.M.	PT	1/A650	1/A650	-	GL-2	-	1.00	-
101	3' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-	-	-	1.01	-
101A	5' - 4"	7' - 4"	D1	H.M.	PT	-	-	-					-	19.00	SEE NOTE #4
102	3' - 0"	7' - 0"	D3	F.R.P.	PREFIN.	F1	F.R.P.	PREFIN.	5/A650	5/A650	7/A650	GL-1	-	6.01	-
102A	12' - 0"	14' - 0"	D4	STL.	PREFIN.	-	-	-	12/A650	16/A650		-	-		SEE NOTE #5
102B	12' - 0"	14' - 0"	D4	STL.	PREFIN.	-	-	-	12/A650	16/A650		-	-		SEE NOTE #5
102C	12' - 0"	14' - 0"	D4	STL.	PREFIN.	-	-	-	12/A650	16/A650		-	-		SEE NOTE #5
102D	12' - 0"	14' - 0"	D4	STL.	PREFIN.	-	-	-	12/A650	16/A650		-	-		SEE NOTE #5
102E	12' - 0"	14' - 0"	D4	STL.	PREFIN.	-	-	-	12/A650	16/A650		-	-		SEE NOTE #5
102F	3' - 0"	7' - 0"	D1	F.R.P.	PREFIN.	F1	F.R.P.	PREFIN.	5/A650	5/A650	7/A650	-	-	6.02	-
103	5' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-			1.20	SEE NOTE #2.
104	5' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-			1.20	SEE NOTE #2.
105	3' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-	-	-	1.02	-
106	3' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-	-	-	1.02	-
107	3' - 0"	7' - 0"	D3	H.M.	PT	F1	H.M.	PT	5/A650	5/A650	-	GL-2	-	1.04	-
107A	3' - 0"	7' - 0"	D1	H.M.	PT	F2	H.M.	PT	3/A650	3/A650	-	-	-	1.04	-
109	3' - 0"	7' - 0"	D1	H.M.	PT	F1	H.M.	PT	1/A650	1/A650	-	-	-	2.00	-
111	3' - 0"	7' - 0"	D2	WD.	ST	F1	H.M.	PT	3/A650	1/A650	-	GL-2	-	5.00	-
112	3' - 0"	7' - 0"	D1	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	-	-	1.01	-
113	3' - 0"	7' - 0"	D3	F.R.P.	PREFIN.	F1	F.R.P.	PREFIN.	5/A650	5/A650	7/A650	GL-1	-	6.04	-
113A	3' - 0"	7' - 0"	D2	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	GL-2	-	1.02	-
113B	6' - 0"	7' - 0"	D1	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	-	-	1.20	SEE NOTE #3
114	3' - 0"	7' - 0"	D1	F.R.P.	PREFIN.	F1	F.R.P.	PREFIN.	5/A650	5/A650	7/A650	-	-	6.03	-
114A	3' - 0"	7' - 0"	D3	H.M.	PT	F1	H.M.	PT	3/A650	3/A650	-	GL-2	-	1.04	-
115	3' - 0"	7' - 0"	D1	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	-	-	2.00	-
116	3' - 0"	7' - 0"	D1	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	-	-	2.00	-
119	3' - 0"	7' - 0"	D2	WD.	ST	F1	H.M.	PT	1/A650	1/A650	-	GL-2	-	5.00	-
200A	6' - 0"	7' - 0"	D1	H.M.	PT	F1	H.M.	PT	6/A650	6/A650	7/A650 SIM.	-	-	4.20	SEE NOTE #3
200B	3' - 0"	7' - 0"	D1	H.M.	PT	F1	H.M.	PT	5/A650	5/A650	13/A650	-	-	4.00	-
201	6' - 0"	7' - 0"	D1	H.M.	PT	F1	H.M.	PT	1/A650	1/A650	-	-	-	1.20	SEE NOTE #3